



ROOF PITCH $\geq 1.5^{\circ}$



ALUMINIUM RIDGE FLASHING RIVETTED TO 'U' TYPE RIDGE CLOSURES AT NOT MORE THAN 305 mm CENTRES WITH $\varnothing 4.8$ mm x APPROX. 12 mm LONG ALUMINIUM BLIND SEALED RIVETS (WITH STAINLESS STEEL MANDREL), OR $\varnothing 5$ mm x APPROX. 20 mm LONG ALUMINIUM 'BULB-TITE' TYPE NEOPRENE SEALED RIVETS (WITH ALUMINIUM MANDREL), RIVET TYPE TO BE DETERMINED BY GAUGE, LENGTH AND SHAPE OF FLASHING

RIDGE CLOSURE

REFER TO DRG. TIS-05-01
FIXED POINT




ALUMINIUM RIDGE FLASHING. FLASHING MAY BE FABRICATED TO VARYING PROFILES TO SUIT AESTHETIC REQUIREMENTS

SUPPORT TO BE GIVEN TO RIDGE FLASHING BY CONTINUOUS EXTRUDED ALUMINIUM 'Z' PROFILE (11950) RIVETTED TO KALZIP SEAMS WITH $\varnothing 4.8$ mm x APPROX. 12 mm LONG ALUMINIUM BLIND SEALED TYPE RIVETS (WITH STAINLESS STEEL MANDREL). DO NOT RIVET AT ST. CLIP POSITIONS

NOTE - FOR RIDGE FIXING DETAILS REFER TO DRG. STD-1-01

CONTINUOUS EXTRUDED 50 x 6 mm ALUMINIUM FLAT BAR (0217), OR 22 x 6 mm ALUMINIUM FLAT BAR (0403) RIVETTED TO KALZIP SEAMS WITH $\varnothing 4.8$ mm x APPROX. 15 mm LONG ALUMINIUM BLIND SEALED TYPE RIVETS (WITH STAINLESS STEEL MANDREL).



1. All Dims in mm Unless Otherwise Stated
2. Do Not Scale From This Drawing
3. Isolate All Dissimilar Materials With Barrier Tape
4. If In Doubt, ASK

N.B. THIS DETAIL IS APPLICABLE WHEN NO VENTILATION IS REQUIRED AT RIDGE POSITION AND WHEN 'FIXED POINT' HAS BEEN INTRODUCED AT RIDGE CLIPS



Kalzip Ltd
Haydock Lane, Haydock, St. Helens
MERSEYSIDE, WA11 9TY
Tel: 01942 717072 Fax: 01942 715713
This drawing is copy/right and is issued on the express condition that it is not to be copied or disclosed by or to any unauthorised person or firms without prior consent in writing from Kalzip.

Project:		Kalzip Standard Details			
Client:		Kalzip Ltd			
Title:		Kalzip Ridge Flashing Fixing Detail			
Scale:	Date:	Drawn:	Checked:		
1:2	13.07.05	KRT			
Dwg No.	KZ-0-STD-K-2-002		Rev	D	