


Notes

1. All Dimensions in mm Unless Otherwise Stated
2. Do Not Scale From This Drawing
3. Isolate All Dissimilar Materials With Barrier Tape
4. If in Doubt, ASK

Compartment walls should be taken to the underside of the liner profile, with the introduction of fire stopping as necessary to the wall / roof junction to maintain the continuity of fire resistance, shaped as required to suit the liner profile.

Double skin metal roofing systems should incorporate a band of material with limited combustibility 1500 mm either side of the compartment wall



- ① Kalzip LINER SHEET
- ② Kalzip VAPOUR CONTROL LAYER (V.C.L)
- ③ HALTER CLIPS
- ④ Kalzip THERMAL INSULATION
- ⑤ TOP SHEET

Revision	Drawn	CHECK'D	Date	Description

Kalzip
A Tria Steel Enterprise

Kalzip Ltd
Haydock Lane, Haydock, St. Helens
MERSEYSIDE, WA11 9TY
Tel: 01942 295 500
Fax: 01942 295 508

This drawing is copyright and is issued on the express condition that it is not to be copied or disclosed by or to any unauthorised person or firms without prior consent in writing from Kalzip.

Project:
Kalzip Standard Details

Client:
Kalzip Ltd

Title: Junction at Compartment Wall			
Scale: NTS	Date: 06.02.04	Drawn: AW	Checked:
Dwg No. RDS-MISC-0-09			Rev: B

The gap to the underside of the liner and the top of the wall should be filled with glassfibre or similar fire stop blocks.

The fire stop blocks should be secured in position using angle trims